

Final Interoperability Test Report

FIT #: **121**
 Date: 12/3/2025
 Location: DNV, Arnhem, Netherlands
 Page 1 of 28

APPLICANT

Company: **EDMP Trading LLC.**

Address: P3-08, The Binary by Omniyat, 32 Marasi Drive Street, Business Bay, 125428 Dubai, UAE

DEVICE		
Device type	Magno 22	
<i>Type indication on MID certificate</i>		<i>MID Certificate No.</i>
Magno 22		M4 69267443 0001
<i>IDIS Specification reference</i>	<i>DNV IDIS Certification run No</i>	<i>Digital signature of the test report.</i>
Package 2 ed. 2.0	2503	4A80664DED340A1DCB80C7814CB90EEA
<i>First certification</i>	<i>IDIS Label</i>	<i>Modular device</i>
<input checked="" type="checkbox"/>	0112	<input type="checkbox"/>
<i>General information about the device</i>		

FIRMWARE VERSIONS TESTED				<i>Final Interoperability Test No. 121</i>
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	Verdict
1	\MAG22.L.A78 40101	\MAG22.N.A7 840101		Passed

Honeywell

Iskraemeco d.d.

Itron

Landis+Gyr (Pty) Ltd

Fit #121

Device: EDMP Trading LLC Magno 22

DNV-GL, Arnhem, Netherlands, 12.03.2025

Page 2 of 28

FIRMWARE VERSIONS HISTORY				Final Integration Test	
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	No.	Verdict
1	\MAG22.L.A784 0101	\MAG22.N.A7 840101		121	Passed

TEST REPORT - Firmware No. 1		
<i>Test</i>	<i>Verdict</i>	<i>Remark</i>
Connect and release	Passed	
All Device IDs	Passed	
COSEM logical device name	Passed	
SAP assignment	Passed	
FW version and signature	Passed	2 Firmware ID's, 2 Signatures
All Device ID's	Passed	
Broadcast Date and time	Passed	
Broadcast Special Days Table	Passed	
Event logs	Passed	
Billing data period 1	Passed	
M-Bus Channel Setup	Not Tested	
M-Bus Results	Not Tested	
M-Bus Devices IDs	Not Tested	
M-Bus profiles	Not Tested	
M-Bus Load profiles	Not Tested	
M-Bus control logs	Not Tested	
M-Bus Disconnect log	Not Tested	
FIT Push	Passed	Power Off Push N/A
FIT Miscellaneous	Passed	Fit Wake Up N/A
Optical Port Connectivity	Passed	
Consumer Information Interface	Not Tested	

FIT Conformance Test Report

```

*****
IDIS Conformance test report
12-MAR-2025 09:42:06
iCTT2 Package 2, Edition 2.0, Revision 1 (136)
Licensed to: KEMA-IDIS Cert.
Tester: Tom Levels
*****

```

```

*****
* Identification *
*****

```

```

Manufacturer = {
  Name = '\EDMP Trading LLC.'
  ThreeLettersId = '\EDP'
}
DeviceUnderTest = {
  Type = '\Magno 22'
  IDISDeviceType = 102
  IDISFunctionType = [EXTENSION_D, EXTENSION_L]
  SerialNr = 3553080
  IPVersion = IPV6
  DataLinkLayer = G3
  ConsumerInformationPush = FALSE
  EUI64Address = '386E21FFFE363738'
  SMSSupported = FALSE
  ClipCallSupported = FALSE
}

```

Active firmware identifier (1-0:0.2.0.255) = \MAG22.L.A7840101

```

Active firmware identifier 1 (1-1:0.2.0.255) = \MAG22.N.A7840101

*****
* Summary *
*****

PASSED                66
FAILED                0
DISABLED              0
INAPPLICABLE         207
INCONCLUSIVE         0
FATAL                0
TOTAL                273

*****
Test Case 1 : Connect and release, 4 item(s)
*****
(1) Connect Public                PASSED
(2) Release Public                PASSED
(3) Connect Management            PASSED
(4) Release Management            PASSED

*****
Test Case 2 : Read Device IDs, 12 item(s)
*****

Mngmt Get Device ID 1, manufacturing number 0-0:96.1.0.255 (@46)
(1) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600100FF" />
    </Data>
(2) .value                        PASSED
    <Data>
      <OctetString Value="\03553080" />
    </Data>

Mngmt Get Device ID 2 0-0:96.1.1.255 (@50)
(3) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600101FF" />
    </Data>
(4) .value                        PASSED
    <Data>
      <OctetString Value="\00000016" />
    </Data>

Mngmt Get Device ID 3 0-0:96.1.2.255 (@54)
(5) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600102FF" />
    </Data>
(6) .value                        PASSED
    <Data>
      <OctetString Value="\3" />
    </Data>

Mngmt Get Device ID 4 0-0:96.1.3.255 (@58)
(7) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600103FF" />
    </Data>
(8) .value                        PASSED
    <Data>
      <OctetString Value="\4" />
    </Data>

Mngmt Get Device ID 5 0-0:96.1.4.255 (@62)
(9) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600104FF" />
    </Data>
(10) .value                       PASSED
    <Data>

```

```

        <OctetString Value="\5" />
    </Data>

Mngmt Get Device ID 6, IDIS certification number 0-0:96.1.5.255 (@66)
(11) .logical_name PASSED
    <Data>
        <OctetString Value="0000600105FF" />
    </Data>
(12) .value PASSED
    <Data>
        <OctetString Value="\6" />
    </Data>

*****
Test Case 3 : Read COSEM Logical Device Name, 2 item(s)
*****

Mngmt Get COSEM logical device name 0-0:42.0.0.255 (@42)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="00002A0000FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\EDP1020303553080" />
    </Data>

*****
Test Case 4 : Read SAP Assignment, 2 item(s)
*****

Mngmt Get SAP Assignment 0-0:41.0.0.255 (@4)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000290000FF" />
    </Data>
(2) .SAP_assignment_list PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <LongUnsigned Value="0001" />
                <OctetString Value="\EDP1020303553080" />
            </Structure>
        </Array>
    </Data>

*****
Test Case 5 : Read Active FW Version, 12 item(s)
*****

Mngmt Get Active firmware identifier 1-0:0.2.0.255 (@412)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0100000200FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\MAG22.L.A7840101" />
    </Data>

Mngmt Get Active firmware signature 1-0:0.2.8.255 (@416)
(3) .logical_name PASSED
    <Data>
        <OctetString Value="0100000208FF" />
    </Data>
(4) .value PASSED
    <Data>
        <OctetString Value="CF5BCD13" />
    </Data>

Mngmt Get Active firmware identifier 1 1-1:0.2.0.255 (@420)
(5) .logical_name PASSED
    <Data>

```

```

        <OctetString Value="0101000200FF" />
    </Data>
(6) .value                                     PASSED
    <Data>
        <OctetString Value="\MAG22.N.A7840101" />
    </Data>

Mngmt Get Active firmware signature 1 1-1:0.2.8.255 (@424)
(7) .logical_name                             PASSED
    <Data>
        <OctetString Value="0101000208FF" />
    </Data>
(8) .value                                     PASSED
    <Data>
        <OctetString Value="AF196C5A" />
    </Data>

Mngmt Get Active firmware identifier 2 1-2:0.2.0.255 (@428)
(9) .logical_name
INAPPLICABLE
    Optional object is not implemented
(10) .value
INAPPLICABLE
    Optional object is not implemented

Mngmt Get Active firmware signature 2 1-2:0.2.8.255 (@432)
(11) .logical_name
INAPPLICABLE
    Optional object is not implemented
(12) .value
INAPPLICABLE
    Optional object is not implemented

*****
Test Case 6 : Set Clock, 1 item(s)
*****

Pre Set Clock 0-0:1.0.0.255 (@75)
(1) .time                                     PASSED
    <Data>
        <OctetString Value="07E9030BFF100000FF8000FF" />
    </Data>

*****
Test Case 7 : Get Clock, 1 item(s)
*****

Mngmt Get Clock 0-0:1.0.0.255 (@75)
(1) .time                                     PASSED
    <Data>
        <OctetString Value="07E9030B0210000100FFC400" />
    </Data>

*****
Test Case 8 : Set Special Days, 1 item(s)
*****

Pre Set Special Days Table 0-0:11.0.0.255 (@125)
(1) .entries                                 PASSED
    <Data>
        <Array Qty="001E" >
            <Structure Qty="0003" >
                <LongUnsigned Value="001E" />
                <OctetString Value="FFFF0101FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001D" />
                <OctetString Value="FFFF0102FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001C" />
            </Structure>
        </Array>
    </Data>

```

```

    <OctetString Value="FFFF0103FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001B" />
    <OctetString Value="FFFF0104FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001A" />
    <OctetString Value="FFFF0105FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0019" />
    <OctetString Value="FFFF0106FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0018" />
    <OctetString Value="FFFF0107FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0017" />
    <OctetString Value="FFFF0108FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0016" />
    <OctetString Value="FFFF0109FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0015" />
    <OctetString Value="FFFF010AFF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0014" />
    <OctetString Value="FFFF0201FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0013" />
    <OctetString Value="FFFF0202FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0012" />
    <OctetString Value="FFFF0203FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0011" />
    <OctetString Value="FFFF0204FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0010" />
    <OctetString Value="FFFF0205FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000F" />
    <OctetString Value="FFFF0206FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000E" />
    <OctetString Value="FFFF0207FF" />
    <Unsigned Value="02" />
  </Structure>

```

```

<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0006" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0005" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0004" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0003" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0002" />
  <OctetString Value="FFFF0309FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0001" />
  <OctetString Value="FFFF030AFF" />
  <Unsigned Value="02" />
</Structure>
</Array>
</Data>

```

```

*****
Test Case 9 : Get Special Days, 1 item(s)
*****

```



```
(1) .entries
  <Data>
    <Array Qty="001E" >
      <Structure Qty="0003" >
        <LongUnsigned Value="001E" />
        <OctetString Value="FFFF0101FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001D" />
        <OctetString Value="FFFF0102FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001C" />
        <OctetString Value="FFFF0103FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001B" />
        <OctetString Value="FFFF0104FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001A" />
        <OctetString Value="FFFF0105FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0019" />
        <OctetString Value="FFFF0106FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0018" />
        <OctetString Value="FFFF0107FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0017" />
        <OctetString Value="FFFF0108FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0016" />
        <OctetString Value="FFFF0109FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0015" />
        <OctetString Value="FFFF010AFF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0014" />
        <OctetString Value="FFFF0201FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0013" />
        <OctetString Value="FFFF0202FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0012" />
        <OctetString Value="FFFF0203FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0011" />
        <OctetString Value="FFFF0204FF" />
        <Unsigned Value="02" />
      </Structure>
    </Array>
  </Data>
```

PASSED

```

<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0006" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0005" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0004" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0003" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0002" />
  <OctetString Value="FFFF0309FF" />

```

```

        <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <LongUnsigned Value="0001" />
        <OctetString Value="FFFF030AFF" />
        <Unsigned Value="02" />
    </Structure>
</Array>
</Data>

*****
Test Case 10 : Read Event Log Buffers, 20 item(s)
*****

Mngmt Get Disconnecter Control Log 0-0:99.98.2.255 (@193)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000636202FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 12-MAR-2025 09:14:43, latest date: 12-MAR-2025 10:47:13
    Middle date: 12-MAR-2025 10:46:26
(3) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000007" />
    </Data>
(4) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

Mngmt Get Standard Event Log 0-0:99.98.0.255 (@301)
(5) .logical_name PASSED
    <Data>
        <OctetString Value="0000636200FF" />
    </Data>
(6) .buffer PASSED
    Earliest date: 11-MAR-2025 16:00:00, latest date: 12-MAR-2025 11:00:34
    Middle date: 12-MAR-2025 10:17:41
(7) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000000D" />
    </Data>
(8) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000001F4" />
    </Data>

Mngmt Get Fraud Detection Log 0-0:99.98.1.255 (@316)
(9) .logical_name PASSED
    <Data>
        <OctetString Value="0000636201FF" />
    </Data>
(10) .buffer PASSED
    Earliest date: 20-JAN-2025 16:01:55, latest date: 15-JUN-2026 03:16:43
    Middle date: 20-JAN-2025 16:02:20
(11) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000007E" />
    </Data>
(12) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="000000C8" />
    </Data>

Mngmt Get Communication Log 0-0:99.98.5.255 (@331)
(13) .logical_name PASSED
    <Data>
        <OctetString Value="0000636205FF" />
    </Data>
(14) .buffer PASSED
    Earliest date: 01-APR-2022 00:01:46, latest date: 20-DEC-2024 17:43:10
    Middle date: 20-DEC-2024 17:40:57

```

(15) .entries_in_use	PASSED
<pre> <Data> <DoubleLongUnsigned Value="00000005" /> </Data> </pre>	
(16) .profile_entries	PASSED
<pre> <Data> <DoubleLongUnsigned Value="000000C8" /> </Data> </pre>	
Mngmt Get Power Quality Log 0-0:99.98.4.255 (@1340)	
(17) .logical_name	PASSED
<pre> <Data> <OctetString Value="0000636204FF" /> </Data> </pre>	
(18) .buffer	PASSED
<pre> Earliest date: 30-JAN-2021 08:30:50, latest date: 11-MAR-2025 15:24:41 Middle date: 20-DEC-2024 18:01:19 </pre>	
(19) .entries_in_use	PASSED
<pre> <Data> <DoubleLongUnsigned Value="00000008" /> </Data> </pre>	
(20) .profile_entries	PASSED
<pre> <Data> <DoubleLongUnsigned Value="000000C8" /> </Data> </pre>	
<pre> ***** Test Case 11 : Reading Data of Billing Period 1, 8 item(s) ***** </pre>	
Mngmt Get Data of billing period 1 0-0:98.1.0.255 (@158)	
(1) .logical_name	PASSED
<pre> <Data> <OctetString Value="0000620100FF" /> </Data> </pre>	
(2) .buffer	PASSED
<pre> Earliest date: 02-MAR-2025 00:00:00, latest date: 02-SEP-2025 00:00:00 Middle date: 02-AUG-2025 00:00:00 </pre>	
(3) .capture_objects	PASSED
<pre> <Data> <Array Qty="0005" > <Structure Qty="0004" > <LongUnsigned Value="0008" /> <OctetString Value="0000010000FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0003" /> <OctetString Value="0100010801FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0003" /> <OctetString Value="0100010802FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0003" /> <OctetString Value="0100020801FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> <Structure Qty="0004" > <LongUnsigned Value="0003" /> <OctetString Value="0100020802FF" /> <Integer Value="02" /> <LongUnsigned Value="0000" /> </Structure> </Array> </Data> </pre>	

```

(4) .capture_period                                     PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(5) .sort_method                                       PASSED
    <Data>
      <Enum Value="01" />
    </Data>
(6) .sort_object                                       PASSED
    <Data>
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
        <OctetString Value="0000010000FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
    </Data>
(7) .entries_in_use                                    PASSED
    <Data>
      <DoubleLongUnsigned Value="0000000B" />
    </Data>
(8) .profile_entries                                  PASSED
    <Data>
      <DoubleLongUnsigned Value="00000018" />
    </Data>

*****
Test Case 12 : Ext. M - M-Bus Setup LGZ G350, 52 item(s)
*****

Mngmt Get M-Bus master port setup 1 0-0:24.6.0.255 (@1566)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .comm_speed
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus master port setup 2 0-1:24.6.0.255 (@1570)
(3) .logical_name
INAPPLICABLE
    Optional object is not implemented
(4) .comm_speed
INAPPLICABLE
    Optional object is not implemented

Mngmt Get M-Bus client channel 1 0-1:24.1.0.255 (@1574)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(9) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .device_type
INAPPLICABLE

```

```

    Object is not required according to OM and/or extensions
(14) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 2 0-2:24.1.0.255 (@1596)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(25) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 3 0-3:24.1.0.255 (@1618)
(29) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(33) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(36) .version
INAPPLICABLE

```

```

    Object is not required according to OM and/or extensions
(37) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 4 0-4:24.1.0.255 (@1640)
(41) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(42) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(43) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(44) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(45) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(46) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(47) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(48) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(49) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(50) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(51) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(52) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

*****
Test Case 13 : Ext. M - M-Bus Results uncorrected Vol. & valve, 40 item(s)
*****

```

```

Mngmt Get M-Bus Value channel 1, instance 1 0-1:24.2.1.255 (@1662)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

Mngmt Get M-Bus Value channel 1, instance 2 0-1:24.2.2.255 (@1670)
(6) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(9) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 2, instance 1 0-2:24.2.1.255 (@1694)
(11) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 2, instance 2 0-2:24.2.2.255 (@1702)
(16) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(17) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 3, instance 1 0-3:24.2.1.255 (@1726)
(21) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(25) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 3, instance 2 0-3:24.2.2.255 (@1734)
(26) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions

```



```

(27) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 4, instance 1 0-4:24.2.1.255 (@1758)
(31) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(33) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 4, instance 2 0-4:24.2.2.255 (@1766)
(36) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 14 : Ext. M - M-Bus Device IDs, 16 item(s)
*****

Mngmt Get M-Bus Device ID 1 channel 1 0-1:96.1.0.255 (@1790)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 2 0-2:96.1.0.255 (@1794)
(3) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 3 0-3:96.1.0.255 (@1798)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .value
INAPPLICABLE

```

```

        Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 4 0-4:96.1.0.255 (@1802)
(7) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 1 0-1:96.1.1.255 (@1806)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 2 0-2:96.1.1.255 (@1810)
(11) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 3 0-3:96.1.1.255 (@1814)
(13) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 4 0-4:96.1.1.255 (@1818)
(15) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 15 : Ext. M - M-Bus Load Profiles, 32 item(s)
*****

Mngmt Get M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)

```

```

(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)
(25) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(32) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 16 : Ext. M - M-Bus Control Logs, 40 item(s)
*****

Mngmt Get M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(21) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)
(25) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Event Log 0-0:99.98.3.255 (@1989)
(33) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(36) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 17 : Ext. M - M-Bus Disconnect, 22 item(s)
*****

Mngmt Get M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(2) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)
(13) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Disconnect control scheduler 0-1:15.0.1.255 (@1914)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .executed_script
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .execution_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Disconnect script table 0-1:10.0.106.255 (@1920)
(21) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .scripts
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

*****
Test Case 18 : FIT Push, 3 item(s)
*****
    (1) Push on installation                                     PASSED
    (2) Push on alarm                                           PASSED
    (3) Push on power down
INAPPLICABLE
    Push setup on power down not available

*****
Test Case 19 : FIT Miscellaneous, 4 item(s)
*****
    (1) Disconnecter Script Table                               PASSED
    (2) Load profile with period 1 DST ambiguity               PASSED
    (3) Load profile power down withing one period             PASSED
    (4) Load profile power down over two periods               PASSED

*****
* CTI *
*****

// Conformance Test Information (CTI) Template
// 2.3

Manufacturer = {
    Name = '\EDMP Trading LLC.'
    ThreeLettersId = '\EDP'
}

DeviceUnderTest = {
    Type = '\Magno 22'
    IDISDeviceType = 102
    IDISFunctionType = [Extension_D, Extension_L]
    SerialNr = 03553080
    IPVersion = IPv6
    DataLinkLayer = G3
    ConsumerInformationPush = FALSE
    EUI64Address = "386E21FFFE363738"

    SMSSupported = FALSE
    ClipCallSupported = FALSE
}

TestOptions = {
    PushDestination = '\[fe80:0:0:0:781d:ff:fe00:0]:61616'
}

ObjectModel = {
    // Optional objects implemented
    // Optional objects implemented
    OptionalObjects = '\
    + '1-1:0.2.0.255|1,' // Active firmware identifier 1 (@420)
    + '1-1:0.2.8.255|1' // Active firmware signature 1 (@424)

    InstanceExtraInfo = {
        // Activity Calendar (@112)
        LogicalName = '0-0:13.0.0.255'
        ClassId = 20
        MethodExtraInfo = {
            // activate_passive_calendar
            MethodId = 1
            AccessRights = [ACTION]
        }
    }

    //Class 91 attribute 5.
    InstanceExtraInfo = {
        // G3-PLC MAC Setup (1277)
        LogicalName = '0-0:29.1.0.255'
        ClassId = 91
    }
}

```

```

        AttributeExtraInfo = {
            //mac_key_table
            AttributeId = 5
            SetData = '\<Data>'
+'          <Array Qty="01" >'
+'            <Structure Qty="02" >'
+'              <Unsigned Value="00" />'
+'              <OctetString Value="AF4D6DCCF14DE7C1C4235E6FEF6C151F" />'
+'            </Structure>'
+'          </Array>'
+'        </Data>'

        }
    }

// Set value for Consumer Message Text
InstanceExtraInfo = {
    LogicalName = '0-0:96.13.0.255'
    ClassId = 1
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
    }
}

InstanceExtraInfo = {
    LogicalName = '0-0:97.98.0.255'
    ClassId = 1
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><DoubleLongUnsigned Value="00000000" /></Data>'
    }
}

InstanceExtraInfo = {
    LogicalName = '0-0:97.98.1.255'
    ClassId = 1
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><DoubleLongUnsigned Value="00000000" /></Data>'
    }
}

InstanceExtraInfo = {
    LogicalName = '0-0:97.97.0.255'
    ClassId = 1
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><DoubleLongUnsigned Value="00000000" /></Data>'
    }
}

InstanceExtraInfo = {
    LogicalName = '0-0:1.0.0.255'
    ClassId = 8
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><OctetString Value="07E9030BFF10000FF8000FF" /></Data>' // yyyy mm
dd dow hh mm ss
    }
}

InstanceExtraInfo = {
    // Set special days to 30 entries
    LogicalName = '0-0:11.0.0.255'
    ClassId = 11
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data>'
+'          <Array Qty="1E" >'
+'            <Structure Qty="03" >'
+'              <LongUnsigned Value="001E" />'
+'              <OctetString Value="FFFF0101FF" />'

```



```

+'          <Unsigned Value="02" />'
+'        </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="001D" />'
+'        <OctetString Value="FFFF0102FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'    <Structure Qty="03" >'
+'      <LongUnsigned Value="001C" />'
+'      <OctetString Value="FFFF0103FF" />'
+'      <Unsigned Value="02" />'
+'    </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="001B" />'
+'    <OctetString Value="FFFF0104FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="001A" />'
+'   <OctetString Value="FFFF0105FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0019" />'
+'   <OctetString Value="FFFF0106FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0018" />'
+'   <OctetString Value="FFFF0107FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0017" />'
+'   <OctetString Value="FFFF0108FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0016" />'
+'   <OctetString Value="FFFF0109FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0015" />'
+'   <OctetString Value="FFFF010AFF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0014" />'
+'   <OctetString Value="FFFF0201FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0013" />'
+'   <OctetString Value="FFFF0202FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0012" />'
+'   <OctetString Value="FFFF0203FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0011" />'
+'   <OctetString Value="FFFF0204FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0010" />'
+'   <OctetString Value="FFFF0205FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'

```

```

+'          <LongUnsigned Value="000F" />'
+'          <OctetString Value="FFFF0206FF" />'
+'          <Unsigned Value="02" />'
+'        </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000E" />'
+'        <OctetString Value="FFFF0207FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'    <Structure Qty="03" >'
+'      <LongUnsigned Value="000D" />'
+'      <OctetString Value="FFFF0208FF" />'
+'      <Unsigned Value="02" />'
+'    </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="000C" />'
+'    <OctetString Value="FFFF0209FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000B" />'
+'   <OctetString Value="FFFF020AFF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="000A" />'
+'   <OctetString Value="FFFF0301FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0009" />'
+'   <OctetString Value="FFFF0302FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0008" />'
+'   <OctetString Value="FFFF0303FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0007" />'
+'   <OctetString Value="FFFF0304FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0006" />'
+'   <OctetString Value="FFFF0305FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0005" />'
+'   <OctetString Value="FFFF0306FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0004" />'
+'   <OctetString Value="FFFF0307FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0003" />'
+'   <OctetString Value="FFFF0308FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0002" />'
+'   <OctetString Value="FFFF0309FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0001" />'
+'   <OctetString Value="FFFF030AFF" />'
+'   <Unsigned Value="02" />'

```

```

+'          </Structure>'
+'          </Array>'
+'        </Data>'
    }
}

TestParameters = {
    ConnectDisconnectDelay = 5000
    ClientSystemTitle = '58585A0102030405'

    ImageTransfer = {
        ImageIdentifier = '\EDMP---Magno22V1.0.001-0002'
        ImageFileName = '\MAG22.N.A7840101-(upgrade test).bin'
        Timeout = 300000
    }

    PushTimeout = 60000
    MinInterWPDUFramesDelay = 1000
    ProfilePeriodsQty = 6
    CaptureDelay = 10000
    ClipCallDuration = 20000

    AutoConnect = {
        Repetitions = 0
        RepetitionDelay = 0
    }

    PushSetup = {
        NumberOfRetries = 1
        RepetitionDelay = 30
    }

    WakeUpDelay = 30000
    DisconnectToSendSMSDelay = 10000
    DataNotificationToDisconnectDelay = 4000
}

RemoteSecurityElements = {
    Public = {
        ContextName = LONG_NAMES
        MechanismName = LOWEST_LEVEL_SECURITY
        Policy = NO_SECURITY
    }
    Management = {
        ContextName = LONG_NAMES_WITH_CIPHERING
        MechanismName = HIGH_LEVEL_SECURITY_GMAC
        Policy = AUTHENTICATION_AND_ENCRYPTION
        Password = '\12345678'
    }
    PreEstablished = {
        Policy = AUTHENTICATION_AND_ENCRYPTION
        ServerMaxReceivePduSize = 1200
        CipheringStyle = GENERAL
    }
}

LocalSecurityElements = {
    Public = {
        ContextName = LONG_NAMES
        MechanismName = LOWEST_LEVEL_SECURITY
        Policy = NO_SECURITY
    }
    Management = {
        ContextName = LONG_NAMES
        MechanismName = LOW_LEVEL_SECURITY
        Policy = NO_SECURITY
        Password = '\12345678'
    }
    PreEstablished = {

```

```

    Policy = NO_SECURITY
    ServerMaxReceivePduSize = 1200
    CipherringStyle = GENERAL
  }
}

SMSSecurityElements = {
  PreEstablished = {
    Policy = AUTHENTICATION_AND_ENCRYPTION
    ServerMaxReceivePduSize = 138
    CipherringStyle = GENERAL
  }
}

HDLCPProfile = {
  PhysicalLayer = {
    OpeningMode = DIRECT_HDLC
    HdlcBaud = 9600
  }
  DataLinkLayer = {
    InactivityTimeout      = 180000
    InterFrameTimeout     = 400
    ResponseTimeout       = 10000
    DISCToNDMTimeout     = 6000
    AddressingSchemes     = [FOUR_BYTES_ADDRESSING]
    ServerLowerMACAddress = 16
  }
}

TCPProfile = {
  ServerTCPPort = 4059
  ResponseTimeout = 10000
  ConnectTimeout = 5000
  DisconnectToConnectDelay = 1000
}

G3PLCProfile = {
  ResponseTimeout = 40000
  FrequencyBand = CENELEC_A
  ConnectTimeout = 20000
  UDPPort = 61616
  PSK = "AF4D6DCCF14DE7C1C4235E6FEF6C151F"
}

// END CTI_Template

*****
* Miscellaneous *
*****

TestMode:                G3-PLC
Test Plan Signature:     BFC18D5882976F2087BC007B67CDC246
Object Model:            IDIS-S02-002 - object model Pack2 Ed2.0 - V2.29 (20200831)-FIT MBUS
Tests G350 (CorrectedAndValve status).xlsx
DUT system title:       4544506630363738
Run number:              2503

```