

Final Interoperability Test Report

FIT #: **116**
 Date: 28/8/2024
 Location: DNV, Arnhem, Netherlands
 Page 1 of 29

APPLICANT

Company: Hexing Electrical Co., Ltd.

Address: 1418-35 Moganshan Road, Shangcheng Industrial Zone, 310011, Hangzhou City, China

DEVICE		
Device type	HXP100DII	
<i>Type indication on MID certificate</i>		<i>MID Certificate No.</i>
HXP100DII with CIU EV500		0120/SGS0691
<i>IDIS Specification reference</i>	<i>DNV IDIS Certification run No</i>	<i>Digital signature of the test report.</i>
Package 2 ed. 2.0	2393	76367B663163518454306FFC820E882E
<i>First certification</i>	<i>IDIS Label</i>	<i>Modular device</i>
<input checked="" type="checkbox"/>	0107	<input checked="" type="checkbox"/>
<i>General information about the device</i>		

FIRMWARE VERSIONS TESTED				<i>Final Interoperability Test No. 115</i>
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	Verdict
1	FP60056V16R004 M003	HXP100.D3.F0.TY0 2.		Passed

Honeywell

Iskraemeco d.d.

Itron

Landis+Gyr AG

Fit #116

Device: Hexing HXP100DII

DNV-GL, Arnhem, Netherlands, 28.08.2024

Page 2 of 29

FIRMWARE VERSIONS HISTORY				Final Integration Test	
Firmware No.	Firmware ID1	Firmware ID2	Firmware ID3	No.	Verdict
1	FP60056V16R004M 003	HXP100.D3.F0.TY0 2.		116	Passed

TEST REPORT - Firmware No. 1		
Test	Verdict	Remark
Connect and release	Passed	
All Device IDs	Passed	
COSEM logical device name	Passed	
SAP assignment	Passed	
FW version and signature	Passed	2 Firmware IDs, 2 Signatures
All Device ID's	Passed	
Broadcast Date and time	Passed	
Broadcast Special Days Table	Passed	
Event logs	Passed	
Billing data period 1	Passed	
M-Bus Channel Setup	Not Tested	
M-Bus Results	Not Tested	
M-Bus Devices IDs	Not Tested	
M-Bus profiles	Not Tested	
M-Bus Load profiles	Not Tested	
M-Bus control logs	Not Tested	
M-Bus Disconnect log	Not Tested	
FIT Push	Passed	Power Off Push N/A
FIT Miscellaneous	Passed	
Optical Port Connectivity	Passed	
Consumer Information Interface	Not Tested	

FIT Conformance Test Report

```

*****
IDIS Conformance test report
28-AUG-2024 09:32:40
iCTT2 Package 2, Edition 2.0, Revision 1 (136)
Licensed to: KEMA-IDIS Cert.
Tester: Tom Levels
*****

```

```

*****
* Identification *
*****

```

```

Manufacturer = {
  Name = '\Hexing Electric Ltd.'
  ThreeLettersId = '\HXE'
}
DeviceUnderTest = {
  Type = '\HXP100DII'
  IDISDeviceType = 102
  IDISFunctionType = [EXTENSION_D, EXTENSION_L]
  SerialNr = 3721
  IPVersion = IPV6
  DataLinkLayer = G3
  EUI64Address = '0000000000003721'
  ConsumerInformationPush = FALSE
  SMSSupported = FALSE
  ClipCallSupported = FALSE
}

```

Active firmware identifier (1-0:0.2.0.255) = \FP60056V16R004M003

```

Active firmware identifier 1 (1-1:0.2.0.255) = \HXP100.D3.F0.TY02.

*****
* Summary *
*****

PASSED                66
FAILED                0
DISABLED              0
INAPPLICABLE         207
INCONCLUSIVE         0
FATAL                0
TOTAL                 273

*****
Test Case 1 : Connect and release, 4 item(s)
*****
(1) Connect Public                PASSED
(2) Release Public                PASSED
(3) Connect Management            PASSED
(4) Release Management            PASSED

*****
Test Case 2 : Read Device IDs, 12 item(s)
*****

Mngmt Get Device ID 1, manufacturing number 0-0:96.1.0.255 (@46)
(1) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600100FF" />
    </Data>
(2) .value                        PASSED
    <Data>
      <OctetString Value="\00003721" />
    </Data>

Mngmt Get Device ID 2 0-0:96.1.1.255 (@50)
(3) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600101FF" />
    </Data>
(4) .value                        PASSED
    <Data>
      <OctetString Value="" />
    </Data>

Mngmt Get Device ID 3 0-0:96.1.2.255 (@54)
(5) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600102FF" />
    </Data>
(6) .value                        PASSED
    <Data>
      <OctetString Value="" />
    </Data>

Mngmt Get Device ID 4 0-0:96.1.3.255 (@58)
(7) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600103FF" />
    </Data>
(8) .value                        PASSED
    <Data>
      <OctetString Value="" />
    </Data>

Mngmt Get Device ID 5 0-0:96.1.4.255 (@62)
(9) .logical_name                PASSED
    <Data>
      <OctetString Value="0000600104FF" />
    </Data>
(10) .value                       PASSED
    <Data>

```

```

        <OctetString Value="\RAMZ RAYANEH" />
    </Data>

Mngmt Get Device ID 6, IDIS certification number 0-0:96.1.5.255 (@66)
(11) .logical_name PASSED
    <Data>
        <OctetString Value="0000600105FF" />
    </Data>
(12) .value PASSED
    <Data>
        <OctetString Value="" />
    </Data>

*****
Test Case 3 : Read COSEM Logical Device Name, 2 item(s)
*****

Mngmt Get COSEM logical device name 0-0:42.0.0.255 (@42)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="00002A0000FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\HXE1020300003721" />
    </Data>

*****
Test Case 4 : Read SAP Assignment, 2 item(s)
*****

Mngmt Get SAP Assignment 0-0:41.0.0.255 (@4)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000290000FF" />
    </Data>
(2) .SAP_assignment_list PASSED
    <Data>
        <Array Qty="0001" >
            <Structure Qty="0002" >
                <LongUnsigned Value="0001" />
                <OctetString Value="\HXE1020300003721" />
            </Structure>
        </Array>
    </Data>

*****
Test Case 5 : Read Active FW Version, 12 item(s)
*****

Mngmt Get Active firmware identifier 1-0:0.2.0.255 (@412)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0100000200FF" />
    </Data>
(2) .value PASSED
    <Data>
        <OctetString Value="\FP60056V16R004M003" />
    </Data>

Mngmt Get Active firmware signature 1-0:0.2.8.255 (@416)
(3) .logical_name PASSED
    <Data>
        <OctetString Value="0100000208FF" />
    </Data>
(4) .value PASSED
    <Data>
        <OctetString Value="5F291B02" />
    </Data>

Mngmt Get Active firmware identifier 1 1-1:0.2.0.255 (@420)
(5) .logical_name PASSED
    <Data>

```

```

        <OctetString Value="0101000200FF" />
    </Data>
(6) .value PASSED
    <Data>
        <OctetString Value="\HXP100.D3.F0.TY02." />
    </Data>

Mngmt Get Active firmware signature 1 1-1:0.2.8.255 (@424)
(7) .logical_name PASSED
    <Data>
        <OctetString Value="0101000208FF" />
    </Data>
(8) .value PASSED
    <Data>
        <OctetString Value="D2F4729C" />
    </Data>

Mngmt Get Active firmware identifier 2 1-2:0.2.0.255 (@428)
(9) .logical_name
INAPPLICABLE
    Optional object is not implemented
(10) .value
INAPPLICABLE
    Optional object is not implemented

Mngmt Get Active firmware signature 2 1-2:0.2.8.255 (@432)
(11) .logical_name
INAPPLICABLE
    Optional object is not implemented
(12) .value
INAPPLICABLE
    Optional object is not implemented

*****
Test Case 6 : Set Clock, 1 item(s)
*****

Pre Set Clock 0-0:1.0.0.255 (@75)
(1) .time PASSED
    <Data>
        <OctetString Value="07E8081CFF10000FF8000FF" />
    </Data>

*****
Test Case 7 : Get Clock, 1 item(s)
*****

Mngmt Get Clock 0-0:1.0.0.255 (@75)
(1) .time PASSED
    <Data>
        <OctetString Value="07E8081C031000000FF8880" />
    </Data>

*****
Test Case 8 : Set Special Days, 1 item(s)
*****

Pre Set Special Days Table 0-0:11.0.0.255 (@125)
(1) .entries PASSED
    <Data>
        <Array Qty="001E" >
            <Structure Qty="0003" >
                <LongUnsigned Value="001E" />
                <OctetString Value="FFFF0101FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001D" />
                <OctetString Value="FFFF0102FF" />
                <Unsigned Value="02" />
            </Structure>
            <Structure Qty="0003" >
                <LongUnsigned Value="001C" />
            </Structure>
        </Array>
    </Data>

```

```

    <OctetString Value="FFFF0103FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001B" />
    <OctetString Value="FFFF0104FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="001A" />
    <OctetString Value="FFFF0105FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0019" />
    <OctetString Value="FFFF0106FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0018" />
    <OctetString Value="FFFF0107FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0017" />
    <OctetString Value="FFFF0108FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0016" />
    <OctetString Value="FFFF0109FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0015" />
    <OctetString Value="FFFF010AFF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0014" />
    <OctetString Value="FFFF0201FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0013" />
    <OctetString Value="FFFF0202FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0012" />
    <OctetString Value="FFFF0203FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0011" />
    <OctetString Value="FFFF0204FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="0010" />
    <OctetString Value="FFFF0205FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000F" />
    <OctetString Value="FFFF0206FF" />
    <Unsigned Value="02" />
  </Structure>
  <Structure Qty="0003" >
    <LongUnsigned Value="000E" />
    <OctetString Value="FFFF0207FF" />
    <Unsigned Value="02" />
  </Structure>

```

```

<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0006" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0005" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0004" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0003" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0002" />
  <OctetString Value="FFFF0309FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0001" />
  <OctetString Value="FFFF030AFF" />
  <Unsigned Value="02" />
</Structure>
</Array>
</Data>

```

```

*****
Test Case 9 : Get Special Days, 1 item(s)
*****

```



```
(1) .entries
  <_Data>
    <Array Qty="001E" >
      <Structure Qty="0003" >
        <LongUnsigned Value="001E" />
        <OctetString Value="FFFF0101FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001D" />
        <OctetString Value="FFFF0102FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001C" />
        <OctetString Value="FFFF0103FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001B" />
        <OctetString Value="FFFF0104FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="001A" />
        <OctetString Value="FFFF0105FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0019" />
        <OctetString Value="FFFF0106FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0018" />
        <OctetString Value="FFFF0107FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0017" />
        <OctetString Value="FFFF0108FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0016" />
        <OctetString Value="FFFF0109FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0015" />
        <OctetString Value="FFFF010AFF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0014" />
        <OctetString Value="FFFF0201FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0013" />
        <OctetString Value="FFFF0202FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0012" />
        <OctetString Value="FFFF0203FF" />
        <Unsigned Value="02" />
      </Structure>
      <Structure Qty="0003" >
        <LongUnsigned Value="0011" />
        <OctetString Value="FFFF0204FF" />
        <Unsigned Value="02" />
      </Structure>
    </Array>
  </_Data>
```

PASSED

```

<Structure Qty="0003" >
  <LongUnsigned Value="0010" />
  <OctetString Value="FFFF0205FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000F" />
  <OctetString Value="FFFF0206FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000E" />
  <OctetString Value="FFFF0207FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000D" />
  <OctetString Value="FFFF0208FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000C" />
  <OctetString Value="FFFF0209FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000B" />
  <OctetString Value="FFFF020AFF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="000A" />
  <OctetString Value="FFFF0301FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0009" />
  <OctetString Value="FFFF0302FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0008" />
  <OctetString Value="FFFF0303FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0007" />
  <OctetString Value="FFFF0304FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0006" />
  <OctetString Value="FFFF0305FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0005" />
  <OctetString Value="FFFF0306FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0004" />
  <OctetString Value="FFFF0307FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0003" />
  <OctetString Value="FFFF0308FF" />
  <Unsigned Value="02" />
</Structure>
<Structure Qty="0003" >
  <LongUnsigned Value="0002" />
  <OctetString Value="FFFF0309FF" />

```

```

        <Unsigned Value="02" />
    </Structure>
    <Structure Qty="0003" >
        <LongUnsigned Value="0001" />
        <OctetString Value="FFFF030AFF" />
        <Unsigned Value="02" />
    </Structure>
</Array>
</_Data>

*****
Test Case 10 : Read Event Log Buffers, 20 item(s)
*****

Mngmt Get Disconnecter Control Log 0-0:99.98.2.255 (@193)
(1) .logical_name PASSED
    <Data>
        <OctetString Value="0000636202FF" />
    </Data>
(2) .buffer PASSED
    Earliest date: 06-JUN-2024 09:25:09, latest date: 10-JUL-2024 11:23:24
    Middle date: 10-JUL-2024 11:13:30
(3) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000025" />
    </Data>
(4) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000064" />
    </Data>

Mngmt Get Standard Event Log 0-0:99.98.0.255 (@301)
(5) .logical_name PASSED
    <Data>
        <OctetString Value="0000636200FF" />
    </Data>
(6) .buffer PASSED
    Earliest date: 10-JUL-2024 00:00:00, latest date: 28-AUG-2024 16:04:32
    Middle date: 28-AUG-2024 08:41:36
(7) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="00000064" />
    </Data>
(8) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000064" />
    </Data>

Mngmt Get Fraud Detection Log 0-0:99.98.1.255 (@316)
(9) .logical_name PASSED
    <Data>
        <OctetString Value="0000636201FF" />
    </Data>
(10) .buffer PASSED
    Earliest date: 06-JAN-2024 09:18:18, latest date: 28-AUG-2024 08:42:54
    Middle date: 07-JUN-2024 18:40:47
(11) .entries_in_use PASSED
    <Data>
        <DoubleLongUnsigned Value="0000002A" />
    </Data>
(12) .profile_entries PASSED
    <Data>
        <DoubleLongUnsigned Value="00000064" />
    </Data>

Mngmt Get Communication Log 0-0:99.98.5.255 (@331)
(13) .logical_name PASSED
    <Data>
        <OctetString Value="0000636205FF" />
    </Data>
(14) .buffer PASSED
    Earliest date: 01-JUN-2024 00:00:09, latest date: 28-AUG-2024 16:03:09
    Middle date: 04-JUL-2024 21:11:36

```

(15)	.entries_in_use	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000018" />	
	</Data>	
(16)	.profile_entries	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000064" />	
	</Data>	
Mngmt Get Power Quality Log 0-0:99.98.4.255 (@1340)		
(17)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0000636204FF" />	
	</Data>	
(18)	.buffer	PASSED
	Earliest date: 06-JUN-2024 09:26:33, latest date: 04-JUL-2024 21:10:18	
	Middle date: 06-JUN-2024 09:34:36	
(19)	.entries_in_use	PASSED
	<Data>	
	<DoubleLongUnsigned Value="00000008" />	
	</Data>	
(20)	.profile_entries	PASSED
	<Data>	
	<DoubleLongUnsigned Value="000000C8" />	
	</Data>	

Test Case 11 : Reading Data of Billing Period 1, 8 item(s)		

Mngmt Get Data of billing period 1 0-0:98.1.0.255 (@158)		
(1)	.logical_name	PASSED
	<Data>	
	<OctetString Value="0000620100FF" />	
	</Data>	
(2)	.buffer	PASSED
	Earliest date: 27-AUG-2024 23:26:45, latest date: 28-AUG-2024 09:19:02	
	Middle date: 28-AUG-2024 03:26:45	
(3)	.capture_objects	PASSED
	<Data>	
	<Array Qty="0005" >	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0008" />	
	<OctetString Value="0000010000FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0003" />	
	<OctetString Value="0100010801FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0003" />	
	<OctetString Value="0100010802FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0003" />	
	<OctetString Value="0100020801FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	<Structure Qty="0004" >	
	<LongUnsigned Value="0003" />	
	<OctetString Value="0100020802FF" />	
	<Integer Value="02" />	
	<LongUnsigned Value="0000" />	
	</Structure>	
	</Array>	
	</Data>	

```

(4) .capture_period                                     PASSED
    <Data>
      <DoubleLongUnsigned Value="00000000" />
    </Data>
(5) .sort_method                                       PASSED
    <Data>
      <Enum Value="01" />
    </Data>
(6) .sort_object                                       PASSED
    <Data>
      <Structure Qty="0004" >
        <LongUnsigned Value="0008" />
        <OctetString Value="0000010000FF" />
        <Integer Value="02" />
        <LongUnsigned Value="0000" />
      </Structure>
    </Data>
(7) .entries_in_use                                    PASSED
    <Data>
      <DoubleLongUnsigned Value="0000000A" />
    </Data>
(8) .profile_entries                                  PASSED
    <Data>
      <DoubleLongUnsigned Value="0000000D" />
    </Data>

*****
Test Case 12 : Ext. M - M-Bus Setup LGZ G350, 52 item(s)
*****

Mngmt Get M-Bus master port setup 1 0-0:24.6.0.255 (@1566)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .comm_speed
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus master port setup 2 0-1:24.6.0.255 (@1570)
(3) .logical_name
INAPPLICABLE
    Optional object is not implemented
(4) .comm_speed
INAPPLICABLE
    Optional object is not implemented

Mngmt Get M-Bus client channel 1 0-1:24.1.0.255 (@1574)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(9) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .device_type
INAPPLICABLE

```

```

    Object is not required according to OM and/or extensions
(14) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 2 0-2:24.1.0.255 (@1596)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(25) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 3 0-3:24.1.0.255 (@1618)
(29) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(33) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(36) .version
INAPPLICABLE

```

```

    Object is not required according to OM and/or extensions
(37) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus client channel 4 0-4:24.1.0.255 (@1640)
(41) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(42) .mbus_port_reference
INAPPLICABLE
    Object is not required according to OM and/or extensions
(43) .capture_definition
INAPPLICABLE
    Object is not required according to OM and/or extensions
(44) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(45) .primary_address
INAPPLICABLE
    Object is not required according to OM and/or extensions
(46) .identification_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(47) .manufacturer_id
INAPPLICABLE
    Object is not required according to OM and/or extensions
(48) .version
INAPPLICABLE
    Object is not required according to OM and/or extensions
(49) .device_type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(50) .access_number
INAPPLICABLE
    Object is not required according to OM and/or extensions
(51) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(52) .alarm
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

*****
Test Case 13 : Ext. M - M-Bus Results uncorrected Vol. & valve, 40 item(s)
*****

```

```

Mngmt Get M-Bus Value channel 1, instance 1 0-1:24.2.1.255 (@1662)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

Mngmt Get M-Bus Value channel 1, instance 2 0-1:24.2.2.255 (@1670)
(6) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(9) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 2, instance 1 0-2:24.2.1.255 (@1694)
(11) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 2, instance 2 0-2:24.2.2.255 (@1702)
(16) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(17) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 3, instance 1 0-3:24.2.1.255 (@1726)
(21) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(25) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 3, instance 2 0-3:24.2.2.255 (@1734)
(26) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions

```



```

(27) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 4, instance 1 0-4:24.2.1.255 (@1758)
(31) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(33) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Value channel 4, instance 2 0-4:24.2.2.255 (@1766)
(36) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .scaler_unit
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .status
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .capture_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 14 : Ext. M - M-Bus Device IDs, 16 item(s)
*****

Mngmt Get M-Bus Device ID 1 channel 1 0-1:96.1.0.255 (@1790)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 2 0-2:96.1.0.255 (@1794)
(3) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 3 0-3:96.1.0.255 (@1798)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .value
INAPPLICABLE

```

```

        Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 1 channel 4 0-4:96.1.0.255 (@1802)
(7) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 1 0-1:96.1.1.255 (@1806)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 2 0-2:96.1.1.255 (@1810)
(11) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 3 0-3:96.1.1.255 (@1814)
(13) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Device ID 2 channel 4 0-4:96.1.1.255 (@1818)
(15) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .value
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 15 : Ext. M - M-Bus Load Profiles, 32 item(s)
*****

Mngmt Get M-Bus Master Load profile for channel 1 0-1:24.3.0.255 (@1838)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 2 0-2:24.3.0.255 (@1849)

```

```

(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 3 0-3:24.3.0.255 (@1860)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(21) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Load profile for channel 4 0-4:24.3.0.255 (@1871)
(25) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(32) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 16 : Ext. M - M-Bus Control Logs, 40 item(s)
*****

Mngmt Get M-Bus Master Control log object 1 0-1:24.5.0.255 (@1941)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(2) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(5) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 2 0-2:24.5.0.255 (@1952)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(13) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 3 0-3:24.5.0.255 (@1963)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(21) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(23) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(24) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Control log object 4 0-4:24.5.0.255 (@1974)
(25) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(26) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(27) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(28) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(29) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(30) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(31) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(32) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Event Log 0-0:99.98.3.255 (@1989)
(33) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(34) .buffer
INAPPLICABLE
    Object is not required according to OM and/or extensions
(35) .capture_objects
INAPPLICABLE
    Object is not required according to OM and/or extensions
(36) .capture_period
INAPPLICABLE
    Object is not required according to OM and/or extensions
(37) .sort_method
INAPPLICABLE
    Object is not required according to OM and/or extensions
(38) .sort_object
INAPPLICABLE
    Object is not required according to OM and/or extensions
(39) .entries_in_use
INAPPLICABLE
    Object is not required according to OM and/or extensions
(40) .profile_entries
INAPPLICABLE
    Object is not required according to OM and/or extensions

*****
Test Case 17 : Ext. M - M-Bus Disconnect, 22 item(s)
*****

Mngmt Get M-Bus Master Disconnect control object 1 0-1:24.4.0.255 (@1882)
(1) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

(2) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(3) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(4) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 2 0-2:24.4.0.255 (@1890)
(5) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(6) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(7) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(8) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 3 0-3:24.4.0.255 (@1898)
(9) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(10) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(11) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(12) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Master Disconnect control object 4 0-4:24.4.0.255 (@1906)
(13) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(14) .output_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(15) .control_state
INAPPLICABLE
    Object is not required according to OM and/or extensions
(16) .control_mode
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Disconnect control scheduler 0-1:15.0.1.255 (@1914)
(17) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(18) .executed_script
INAPPLICABLE
    Object is not required according to OM and/or extensions
(19) .type
INAPPLICABLE
    Object is not required according to OM and/or extensions
(20) .execution_time
INAPPLICABLE
    Object is not required according to OM and/or extensions

Mngmt Get M-Bus Disconnect script table 0-1:10.0.106.255 (@1920)
(21) .logical_name
INAPPLICABLE
    Object is not required according to OM and/or extensions
(22) .scripts
INAPPLICABLE
    Object is not required according to OM and/or extensions

```

```

*****
Test Case 18 : FIT Push, 3 item(s)
*****
    (1) Push on installation                                     PASSED
    (2) Push on alarm                                           PASSED
    (3) Push on power down
INAPPLICABLE
    Push setup on power down not available

*****
Test Case 19 : FIT Miscellaneous, 4 item(s)
*****
    (1) Disconnecter Script Table                               PASSED
    (2) Load profile with period 1 DST ambiguity               PASSED
    (3) Load profile power down withing one period             PASSED
    (4) Load profile power down over two periods               PASSED

*****
* CTI *
*****

// Conformance Test Information (CTI) Template
// 2.3

Manufacturer = {
    Name = '\Hexing Electric Ltd.'
    ThreeLettersId = '\HXE'
}

DeviceUnderTest = {

    Type = '\HXP100DII'
    IDISDeviceType = 102
    IDISFunctionType = [Extension_D, Extension_L]
    SerialNr = 00003721
    IPVersion = IPv6
    DataLinkLayer = G3
    EUI64Address = "0000000000003721"
    ConsumerInformationPush = FALSE
    SMSSupported = FALSE
    ClipCallSupported = FALSE
}

TestOptions = {
    PushDestination = '\[fe80:0:0:0:781d:ff:fe00:0]:61616'
}

ObjectModel = {
    // Optional objects implemented
    OptionalObjects = '\
    + '1-1:0.2.0.255|1,' // Active firmware identifier 1 (@420)
    + '1-1:0.2.8.255|1' // Active firmware signature 1 (@424)

InstanceExtraInfo = {
    // Current association (@9)
    LogicalName = '0-0:40.0.0.255'
    ClassId = 15
    AttributeExtraInfo = {
        // secret
        AttributeId = 7
        SetData = '\<Data><OctetString Value = "3132333435363738" /></Data>'
        AccessRights = [SET]
    }
    MethodExtraInfo = {
        // change_HLS_secret
        MethodId = 2
        AccessRights = [ACTION]
    }
}

InstanceExtraInfo = {
    // Activity Calendar (@112)

```

```

LogicalName = '0-0:13.0.0.255'
ClassId = 20
MethodExtraInfo = {
    // activate_passive_calendar
    MethodId = 1
    AccessRights = [ACTION]
}
}

InstanceExtraInfo = {
    // Predefined Scripts - MDI reset / end of billing period (@147)
    LogicalName = '0-0:10.0.1.255'
    ClassId = 9
    AttributeExtraInfo = {
        // scripts
        AttributeId = 2
        AccessRights = [GET]
    }
}

InstanceExtraInfo = {
    // Predefined Scripts - Image activation (@407)
    LogicalName = '0-0:10.0.107.255'
    ClassId = 9
    AttributeExtraInfo = {
        // scripts
        AttributeId = 2
        AccessRights = [GET]
    }
}

InstanceExtraInfo = {
    LogicalName = '0-1:96.3.10.255'
    ClassId = 70
    AttributeExtraInfo = {
        // control_mode
        AttributeId = 4
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    LogicalName = '0-0:17.0.0.255'
    ClassId = 71
    AttributeExtraInfo = {
        // type
        AttributeId = 11
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo = {
    // Push action scheduler - Interval_3 (@2156)
    LogicalName = '0-0:2.1.0.255'
    ClassId = 29
    AttributeExtraInfo = {
        // type
        AttributeId = 6
        AccessRights = [GET,SET]
    }
}

InstanceExtraInfo =
{
    LogicalName = '0-0:29.1.0.255'
    ClassId = 91
    Version = 1

    AttributeExtraInfo =
    {
        AttributeId = 5
        SetData = '\ ' +
            '<Data>' +

```



```

        ' <Array Qty = "01">' +
        '   <Structure Qty = "02">' +
        '     <Unsigned Value = "01" />' +
        '     <OctetString Value = "FFFFFFFFFFFFFFFFFFFFFFFFFFFFFFFF" />' +
        '   </Structure>' +
        ' </Array>' +
        '</Data>'
        AccessRights = [SET]
    }

InstanceExtraInfo = {
// Set value for Consumer Message Text
LogicalName = '0-0:96.13.0.255'
ClassId = 1
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><OctetString Value="3132333435363738" /></Data>'
    }
}

InstanceExtraInfo = {
LogicalName = '0-0:1.0.0.255'
ClassId = 8
    AttributeExtraInfo = {
        AttributeId = 2
        SetData = '\<Data><OctetString Value="07E8081CFF10000FF8000FF" /></Data>' // yyyy mm
dd dow hh mm ss
    }
}

InstanceExtraInfo = {
// Set special days to 30 entries
LogicalName = '0-0:11.0.0.255'
ClassId = 11
    AttributeExtraInfo = {
        SetData = '\<Data>'
+       <Array Qty="1E" >'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001E" />'
+       <OctetString Value="FFFF0101FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001D" />'
+       <OctetString Value="FFFF0102FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001C" />'
+       <OctetString Value="FFFF0103FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001B" />'
+       <OctetString Value="FFFF0104FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="001A" />'
+       <OctetString Value="FFFF0105FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="0019" />'
+       <OctetString Value="FFFF0106FF" />'
+       <Unsigned Value="02" />'
+       </Structure>'
+       <Structure Qty="03" >'
+       <LongUnsigned Value="0018" />'
+       <OctetString Value="FFFF0107FF" />'
+       <Unsigned Value="02" />'

```

```

+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0017" />'
+'        <OctetString Value="FFFF0108FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0016" />'
+'        <OctetString Value="FFFF0109FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0015" />'
+'        <OctetString Value="FFFF010AFF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0014" />'
+'        <OctetString Value="FFFF0201FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0013" />'
+'        <OctetString Value="FFFF0202FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0012" />'
+'        <OctetString Value="FFFF0203FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0011" />'
+'        <OctetString Value="FFFF0204FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0010" />'
+'        <OctetString Value="FFFF0205FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000F" />'
+'        <OctetString Value="FFFF0206FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000E" />'
+'        <OctetString Value="FFFF0207FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000D" />'
+'        <OctetString Value="FFFF0208FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000C" />'
+'        <OctetString Value="FFFF0209FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000B" />'
+'        <OctetString Value="FFFF020AFF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="000A" />'
+'        <OctetString Value="FFFF0301FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0009" />'

```

```

+'          <OctetString Value="FFFF0302FF" />'
+'          <Unsigned Value="02" />'
+'        </Structure>'
+'      <Structure Qty="03" >'
+'        <LongUnsigned Value="0008" />'
+'        <OctetString Value="FFFF0303FF" />'
+'        <Unsigned Value="02" />'
+'      </Structure>'
+'    <Structure Qty="03" >'
+'      <LongUnsigned Value="0007" />'
+'      <OctetString Value="FFFF0304FF" />'
+'      <Unsigned Value="02" />'
+'    </Structure>'
+'  <Structure Qty="03" >'
+'    <LongUnsigned Value="0006" />'
+'    <OctetString Value="FFFF0305FF" />'
+'    <Unsigned Value="02" />'
+'  </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0005" />'
+'   <OctetString Value="FFFF0306FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0004" />'
+'   <OctetString Value="FFFF0307FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0003" />'
+'   <OctetString Value="FFFF0308FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0002" />'
+'   <OctetString Value="FFFF0309FF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' <Structure Qty="03" >'
+'   <LongUnsigned Value="0001" />'
+'   <OctetString Value="FFFF030AFF" />'
+'   <Unsigned Value="02" />'
+' </Structure>'
+' </Array>'
+' </Data>'
+'
+' }
+'
+' }

```

```

TestParameters = {
    ConnectDisconnectDelay = 10000
    ClientSystemTitle = '58585A0102030405'

    ImageTransfer = {
        ImageIdentifier = '\UPSHXP100.D3.F1.TY02'
        ImageFileName = '\HXP100.D3.F1.TY02.bin'
        Timeout = 90000
    }

    PushTimeout = 90000
    MinInterWPDUFramesDelay = 1000
    ProfilePeriodsQty = 6
    CaptureDelay = 10000
    ClipCallDuration = 12000

    AutoConnect = {
        Repetitions = 0
        RepetitionDelay = 0
    }
}

```

```

PushSetup = {
    NumberOfRetries = 0
    RepetitionDelay = 0
}

WakeUpDelay = 30000
DisconnectToSendSMSDelay = 5000
DataNotificationToDisconnectDelay = 1000
}

LocalSecurityElements = {
    Public = {
        ContextName = LONG_NAMES
        MechanismName = LOWEST_LEVEL_SECURITY
        Policy = NO_SECURITY
    }
    Management = {
        ContextName = LONG_NAMES_WITH_CIPHERING
        MechanismName = HIGH_LEVEL_SECURITY_GMAC
        Policy = AUTHENTICATION_AND_ENCRYPTION
        Password = '\12345678'
    }
    PreEstablished = {
        Policy = NO_SECURITY
        ServerMaxReceivePduSize = 1224
        CipheringStyle = GENERAL
    }
}

RemoteSecurityElements = {
    Public = {
        ContextName = LONG_NAMES
        MechanismName = LOWEST_LEVEL_SECURITY
        Policy = NO_SECURITY
    }
    Management = {
        ContextName = LONG_NAMES_WITH_CIPHERING
        MechanismName = HIGH_LEVEL_SECURITY_GMAC
        Policy = AUTHENTICATION_AND_ENCRYPTION
        Password = '\12345678'
    }
    PreEstablished = {
        Policy = AUTHENTICATION_AND_ENCRYPTION
        ServerMaxReceivePduSize = 1224
        CipheringStyle = GENERAL
    }
}

SMSSecurityElements = {
    PreEstablished = {
        Policy = AUTHENTICATION_AND_ENCRYPTION
        ServerMaxReceivePDUSize = 138
        CipheringStyle = GENERAL
    }
}

HDLCPProfile = {
    PhysicalLayer = {
        OpeningMode = DIRECT_HDLC
        HdlcBaud = 9600
    }
    DataLinkLayer = {
        InactivityTimeout = 120000
        InterFrameTimeout = 150
        ResponseTimeout = 3000
        DISCToNDMTimeout = 1000
        AddressingSchemes = [TWO_BYTES_ADDRESSING]
        ServerLowerMACAddress = 0x11
        LastRecToNextSendDelay = 0
    }
}

```

```

    }

    UIFrameDelay = 2000

    UIFrameLength = 126

}

TCPProfile = {
    ServerTCPPort = 4059
    ResponseTimeout = 10000
    ConnectTimeout = 30000
    DisconnectToConnectDelay = 15000
}

// Mandatory parameters of the ''Remote'' G3-PLC profile
G3PLCProfile = {
    FrequencyBand = FCC
    ResponseTimeout = 30000
    UDPPort = 61616
    ConnectTimeout = 10000
    PSK = "000102030405060708090A0B0C0D0E0F"
}

// END CTI_Templatem

*****
* Miscellaneous *
*****

TestMode:                G3-PLC
Test Plan Signature:     BFC18D5882976F2087BC007B67CDC246
Object Model:            IDIS-S02-002 - object model Pack2 Ed2.0 - V2.29 (20200831)-FIT MBUS
Tests G350 (CorrectedAndValve status).xlsx
DUT system title:       4858456630000E89
Run number:              2393

```